

TECHNICAL REPORT



Short-circuit currents in three-phase AC systems – Part 4: Examples for the calculation of short-circuit currents



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2021 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC online collection - oc.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 18 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

TECHNICAL REPORT



Short-circuit currents in three-phase AC systems – Part 4: Examples for the calculation of short-circuit currents

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 17.220.01; 29.240.20

ISBN 978-2-8322-9932-6

Warning! Make sure that you obtained this publication from an authorized distributor.

[This is a preview. Click here to purchase the full publication.](#)

CONTENTS

FOREWORD.....	6
1 Scope.....	8
2 Normative references	8
3 Terms and definitions, symbols and indices, and formulae.....	8
4 Positive-sequence, negative-sequence and zero-sequence impedances of electrical equipment	9
4.1 General.....	9
4.2 Overhead lines, cables and short-circuit current-limiting reactors.....	9
4.3 Transformers	10
4.3.1 General	10
4.3.2 Example	15
4.4 Generators and power station units.....	17
4.4.1 General	17
4.4.2 Example	20
5 Calculation of short-circuit currents in a low-voltage system $U_n = 400 \text{ V}$	22
5.1 Problem	22
5.2 Determination of the positive-sequence impedances.....	22
5.2.1 Network feeder	22
5.2.2 Transformers	23
5.2.3 Lines (cables and overhead lines)	24
5.3 Determination of the zero-sequence impedances	24
5.3.1 Transformers	24
5.3.2 Lines (cables and overhead lines)	25
5.4 Calculation of I_k'' and i_p for three-phase short circuits	25
5.4.1 Short-circuit location F1.....	25
5.4.2 Short-circuit location F2.....	27
5.4.3 Short-circuit location F3.....	28
5.5 Calculation of I_{k1}'' and i_{p1} for line-to-earth short circuits.....	28
5.5.1 Short-circuit location F1.....	28
5.5.2 Short-circuit location F2.....	29
5.5.3 Short-circuit location F3.....	29
5.6 Collection of results	30
6 Calculation of three-phase short-circuit currents in a medium-voltage system – Influence of asynchronous motors	31
6.1 Problem	31
6.2 Complex calculation with absolute quantities	31
6.3 Calculation with per-unit quantities	35
6.4 Calculation with the superposition method	37
7 Calculation of three-phase short-circuit currents for a power station unit and the auxiliary network.....	40
7.1 Problem	40
7.2 Short-circuit impedances of electrical equipment.....	43
7.2.1 Network feeder	43
7.2.2 Power station unit.....	43
7.2.3	44

7.2.4	Low-voltage transformers 2,5 MVA and 1,6 MVA	45
7.2.5	Asynchronous motors	49
7.3	Calculation of short-circuit currents	49
7.3.1	Short-circuit location F1	49
7.3.2	Short-circuit location F2	50
7.3.3	Short-circuit location F3	51
7.3.4	Short-circuit location F4	55
7.3.5	Short-circuit location F5	57
8	Calculation of three-phase short-circuit currents in a wind power plant	59
8.1	General	59
8.2	Problem	59
8.3	Data and short-circuit impedances of electrical equipment	60
8.4	Nodal admittance and nodal impedance matrices	62
8.5	Short-circuit currents for the wind power plant with ten wind power station units WD	63
8.6	Short-circuit currents for the wind power plant with ten wind power station units WF	65
8.7	Short-circuit currents for the wind power plant with five wind power station units WD and five wind power station units WF	68
9	Test network for the calculation of short-circuit currents with digital programs in accordance with IEC 60909-0	72
9.1	General	72
9.2	High-voltage test network 380 kV/110 kV/30 kV/10 kV	73
9.2.1	Network topology and data	73
9.2.2	Short-circuit impedances of electrical equipment	76
9.3	Results	77
9.3.1	General	77
9.3.2	Three-phase short-circuit currents	78
9.3.3	Line-to-earth short-circuit currents	78
	Bibliography	80

Figure 1 – Positive-sequence and zero-sequence impedances of an overhead line (one circuit) and cable (cross-bonded) 9

Figure 2 – Positive-sequence and zero-sequence impedance of a short-circuit current-limiting reactor 10

Figure 3 – Positive-sequence and zero-sequence system impedances of a two-winding transformer YNd5..... 11

Figure 4 – Equivalent circuits of a three-winding network transformer 15

Figure 5 – Short circuit at the high-voltage side of a power station unit with on-load tap changer 19

Figure 6 – Low-voltage system $U_n = 400$ V with short-circuit locations F1, F2, F3 22

Figure 7 – Positive-sequence system (according to Figure 6) for the calculation of I_k'' at the short-circuit location F1..... 26

Figure 8 – Positive-sequence, negative-sequence and zero-sequence system with connections at the short-circuit location F1 for the calculation of I_{k1}'' 29

Figure 9 – Medium-voltage network 33 kV/6 kV: data 32

Figure 10 – Short-circuit current $I''_{k(T1,T2)S}$ calculated by the superposition method (S) compared with $I''_{k(T1,T2)IEC}$ calculated by the IEC method of equivalent voltage source at the short-circuit location, depending on the load S^b and the voltage U^b	39
Figure 11 – Short-circuit current I''_{kS} calculated by the superposition method (S) compared with I''_{kIEC} calculated by the IEC method of equivalent voltage source at the short-circuit location, depending on the transformation ratio t before the short circuit.....	40
Figure 12 – Power station unit (generator and unit transformer with on-load tap-changer) and auxiliary network with medium- and low-voltage asynchronous motors: data	42
Figure 13 – Positive-sequence system for the calculation of the short-circuit currents at the location F3 (see Figure 12)	52
Figure 14 – Positive-sequence system for the calculation of the short-circuit currents at the location F4 (see Figure 12)	55
Figure 15 – Positive-sequence system for the calculation of the short-circuit currents at the location F5 (see Figure 12)	57
Figure 16 – Windfarm with ten wind power station units	60
Figure 17 – Equivalent circuit diagram for the calculation of the short-circuit current at the location F1 without the consideration of the internal wind power plant cables (values are related to the 20 kV voltage level), variant 1	64
Figure 18 – Equivalent circuit diagram for the calculation of the short-circuit current at the location F1 without the consideration of the internal wind power plant cables (values are related to the 20 kV voltage level), variant 2	67
Figure 19 – Equivalent circuit diagram for the calculation of the short-circuit current at the location F1 without the consideration of the internal wind power plant cables (values are related to the 20 kV voltage level), variant 3	70
Figure 20 – High-voltage AC test network 380 kV/110 kV/30 kV/10 kV	74
Table 1 – Examples for equivalent circuit-diagrams of transformers in the positive-sequence and the zero-sequence system	12
Table 2 – Approximations for the ratios $X_{(0)T}/X_T$ of two- and three-winding transformers	15
Table 3 – Data of electrical equipment for the example in Figure 6 – Positive-sequence and zero-sequence impedances ($Z_{(2)} = Z_{(1)}$).....	23
Table 4 – Short-circuit impedances and short-circuit currents	30
Table 5 – Joule integral depending on T_k at the short-circuit location F2 and F3.....	30
Table 6 – Calculation of the short-circuit impedances of electrical equipment and $Z_{k(T1,T2)}$ at the short-circuit location F, without motors (circuit-breakers CB1 and CB2 are open)	33
Table 7 – Calculation of the per-unit short-circuit reactances of electrical equipment and $*X_{k(T1,T2)}$ at the short-circuit location F	36
Table 8 – Data of transformers 10 kV/0,73 kV and 10 kV/0,42 kV, data of low-voltage motor groups and partial short-circuit currents of these motor groups on busbars B and C respectively	47
Table 9 – Data of medium-voltage asynchronous motors and their partial short-circuit currents at short-circuit locations on busbars B and C respectively	48
Table 10 – Data and impedances of the electrical equipment (see Figure 16) referred to the 20 kV side	61

Table 11 – The diagonal elements of the nodal admittance matrices for the three variants in $1/\Omega$	62
Table 12 – Short-circuit impedances and short-circuit currents at F1 to F14 for wind power stations units with doubly fed asynchronous generators WD	63
Table 13 – Short-circuit impedances and short-circuit currents at F1 to F3 for wind power stations units with doubly fed asynchronous generators WD neglecting the internal wind power plant cables	64
Table 14 – Quotients Z_{ij}/Z_{kFi} for $i = 1$ to 14 and $j = 3...6, 8...10, 12...14$ and the sum of the columns	66
Table 15 – Short-circuit impedances and short-circuit currents at F1 to F14 for wind power stations units with full size converters WF	66
Table 16 – Short-circuit impedances and short-circuit currents at F1 to F3 for wind power stations units with full size converters WF neglecting the internal wind power plant cables	68
Table 17 – Quotients Z_{ij}/Z_{kFi} for $i = 1$ to 14 and $j = 3, 10, 12, 13, 14$ and the sum of the columns	69
Table 18 – Short-circuit impedances and short-circuit currents at F1 to F14 for five wind power stations units with doubly fed asynchronous generators WD and five wind power station units with full size converters WF	69
Table 19 – Short-circuit impedances and short-circuit currents at F1 to F3 for five wind power stations units with doubly fed asynchronous generators WD and five wind power station units with full size converters WF neglecting the internal wind power plant cables	71
Table 20 – Overhead lines and cables	76
Table 21 – Impedances (corrected if necessary) of the electrical equipment (see Figure 20) referred to the 110 kV side with $Z_{(2)} = Z_{(1)}$	77
Table 22 – Results I_k'' , i_p , I_b and I_k	78
Table 23 – Results I_k'' and i_{p1}	79

INTERNATIONAL ELECTROTECHNICAL COMMISSION

SHORT-CIRCUIT CURRENTS IN THREE-PHASE AC SYSTEMS –**Part 4: Examples for the calculation of short-circuit currents**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TR 60909-4 has been prepared by IEC technical committee 73: Short-circuit currents. It is a Technical Report.

This second edition cancels and replaces the first edition published in 2000. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) adaption to IEC 60909-0:2016;
- b) addition of an example for the calculation of short-circuit currents of wind power station units;
- c) correction of errors.

The text of this Technical Report is based on the following documents:

Draft	Report on voting
73/187/DTR	73/193/RVDTR

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Report is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

A list of all parts in the IEC 60909 series, published under the general title *Short-circuit currents in three-phase AC systems*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.